



MAGTFTC-MCAGCC 29 Palms

Environmental Standard Operating Procedure



1 October 2025

Spill Response and Abatement (ABA)

Application and Purpose

This guidance applies to those individuals who are involved in the process of identifying a hazardous material spill and who are trained to clean up and remediate hazardous material spills aboard Marine Air Ground Task Force Training Command (MAGTFTC), Marine Corps Air Ground Combat Center (MCAGCC) Twentynine Palms. For further references to MAGTFTC, MCAGCC in this document, the term "installation" will be used.

This document provides environmental protection guidelines for abatement procedures.

Procedures

Spill response and abatement procedures on base require that spills are cleaned up immediately with prompt notification made to EA. All required notifications outside of the installation will be made by EA staff only. All spills will be handled according to specific clean up and notification procedures, depending on where the spill occurred aboard the installation

Operational Controls

The following controls apply:

- Follow all spill response procedures as outlined in the attachments.
- Ensure all waste generated from spills is turned in within 72 hours to the Hazardous Waste Management Branch, Building 2095, Rifle Range Road.
- Post a copy of the "Spill Response Flow Chart" in common areas to include turnover folders, duty binders, Satellite Accumulation Areas, maintenance bays, and other official areas.
- If there are any specific situations or other concerns not addressed by this document, contact the EA Division Abatement Chief at 760-401-9841, 760-830-7244, or 760-830-5403.
- All generators, lighting systems, and refueling trucks (for example, flat rack refueling capability [FRC] and six containers [SIXCONs]) must be placed within a secondary containment.
- FRCs and SIXCONs that contain fuel are not to be stored on bare ground or pop-up containments. Concrete containments are authorized for storage of empty FRCs and SIXCON.
- All units/commands will be responsible for performing cleanup of spills or releases in the unit area of responsibility as identified in reference (b).

Training Requirements

All affected personnel must be trained in this document and the following:

- General Environmental Awareness training

Recordkeeping

There is no required record keeping for this ESOP.

Emergency Preparedness and Response Procedures

Refer to the Integrated Contingency and Operations Plan and spill response procedures listed in the Abatement ESOP.

Inspection and Corrective Action

The Environmental Compliance Coordinator (ECC) will confirm unit adherence to this ESOP. The ECC will confirm that unit personnel are trained in this ESOP and maintain appropriate documentation in accordance with this ESOP. If this ESOP contains an enclosed inspection checklist, designated personnel will conduct the inspections using this ESOP as guidance and document the inspections via the enclosed checklist. If deficiencies are discovered during an inspection, the ECC will ensure immediate corrective action is taken and that all deficiencies and corrective actions are recorded on the enclosed checklist.

References

- (a) Integrated Contingency and Operations Plan
- (b) 11000.1K Area Clean-Up and Responsibilities for the Combat Center

Use and Version Control

ESOPs are used to augment instructions contained in official orders and directives, and, where necessary, provide for sufficient control of the installation's significant practices. Environmental Affairs maintains the authoritative, current version of this and other ESOPs on the installation's website: <https://www.29palms.marines.mil/Staff-Offices/G-4-Installation-Support-Directorate/Environmental-Affairs/#environmental-sops>

SPILL RESPONSE NOTIFICATION PROCEDURES

IF SPILL OCCURS IN “*Training Areas*”

Contact BEARMAT: 760-830-6535

IF A LARGE SPILL (55 gallons or more**)**

OCCURS ON MAINSIDE OR CAMP WILSON

1. Contact the Fire Department - Base phones “911”; cell phones 830-3333
2. AND Environmental Affairs (EA) Division, Abatement Chief: 760-401-9841

IF A SMALL SPILL (less than 55 gallons**)**

OCCURS ON MAINSIDE OR CAMP WILSON

1. Contact your Unit Environmental Compliance Coordinator_____
2. AND Environmental Affairs (EA) Division, Abatement Chief: 760-401-9841